

		Oct. 2005	Oct. 2006	Jan. 2008
Available Cooling for New Hardware (tons)				
	BLDR-1	0	0	72
	BLDR-2	0	124	124
	PRTN	51	344	344
	GRBLT	0	260	260
	TOTAL	51	728	800

Assumptions for Projections

Available Raised Floor Space:

Floor space offered but not utilized by the Contractor's equipment may be used by the Government for other projects, after discussions with the incumbent.

BLDR:

(1) July 19, 2006 estimate of 1424 ft. is solely in BLDR-2 and assumes completion of computer room design, construction and testing for availability by July 18, 2006.

(2) If the incumbent uses GFE HSMS beginning in FY2008 that currently resides in BLDR-1, then the power, cooling and space used by the GFE HSMS is available to continue supporting the GFE HSMS.

PRTN:

(1) Oct. 2005 number is an estimate derived from the unoccupied raised floor space for the room layout as indicated in Figure 13a, which shows the assumed positions of systems and Storage Tek silos after the mid-contract installation is complete. (The actual square footage of free space is obviously subject to interpretation to account for obstructions such as room columns and ramps, size of equipment to be installed, etc.)

(2) Oct. 2006 estimate reflects available space occupied by systems leased under current Raytheon contract, because this leased equipment will be removed at the end of the current contract. In reality, the new Contractor shall be required to coordinate new equipment installation with current system removal so as to minimize loss of compute cycles to the Government.